SIEMENS



Actuators

SQN3... SQN4...

Electromotoric actuators for use with air dampers and control valves of oil or gas burners of small to medium capacity.

The SQN3... / SQN4... and this Data Sheet are intended for use by OEMs which integrate the actuators in their products!

Use	e / features		
		 SQN3 / SQN4 actuators are designed to drive gas and air dampers on sma dium-capacity oil or gas burners or for the load-dependent control of fuel and houstion air volume: In connection with P-PI or PID controllers, such as the RWF Directly via the different types of burner controls, such as LOA, LMO, LMG. LFL In connection with 1- or 2-wire control or 3-position controllers 	
•	All types of actuators with:	npact-proof and heat-resistant plastic housing crew terminals for the electrical connections aintenance-free gear train, which can be disengaged ternal and external position indication asy-to-adjust end and auxiliary switches for setting the switching points	
•	Holding torque:	QN3 0.83 Nm QN4 6 Nm	
•	Running time:	QN3 4.530 s QN4 120 s	
•	Direction of rotation:	QN30 counterclockwise QN31 / SQN41 clockwise	

Warning notes

To avoid injury to persons, damage to property or the environment, the following warning notes must be observed! Do not interfere with or modify the actuators! All activities (mounting, installation and service work, etc.) must be performed by qualified staff Before making any wiring changes in the connection area of the actuators, • completely isolate the equipment from the mains supply (all-polar disconnection). Ensure that the plant cannot be inadvertently switched on again and that it is indeed dead. If not observed, there is a risk of electric shock hazard Ensure protection against electric shock hazard by providing adequate protection • for the connection terminals and by securing the housing cover Each time work has been carried out (mounting, installation, service work, etc.), ٠ check to ensure that wiring is in an orderly state Fall or shock can adversely affect the safety functions. Such actuators must not be • put into operation, even if they do not exhibit any damage Mounting notes Ensure that the relevant national safety regulations are complied with Standards and certificates Applied directives: Low-voltage directive 2014/35/EC Electromagnetic compatibility EMC (immunity) 2014/30/EC Compliance with the regulations of the applied directives is verified by the adherence to the following standards / regulations: Automatic electrical controls for household and similar use DIN EN 60730-1 Part 1: General requirements Automatic electrical controls for household and similar use DIN EN 60730-2-14 . Part 2-14: Particular requirements for electric actuators The relevant valid edition of the standards can be found in the declaration of conformity! EAC Conformity mark (Eurasian Conformity mark) ISO 9001:2008 ISO 14001:2004 OHSAS 18001:2007 **Disposal notes** The actuator contains electrical and electronic components and must not be disposed



of together with domestic waste.

Local and currently valid legislation must be observed.

Mechanical design

Mechanical design	
Housing	 Made of impact-proof and heat-resistant plastic The housing accommodates: The reversible synchronous motor with gear train, which can be disengaged The camshaft of the control section The relays (depending on the type of actuator) The switches, connected to the terminals via the printed circuit board
	Color: Gear train housing light-grey, cover dark-grey
Drive motor	- Reversible and locking-proof synchronous motor
Coupling	 Shaft can be disengaged from gear train and motor via manual operation of a couplerpressure pin «K» Automatic reengagement
Adjustment of switching points	 With adjustable cams Scales beside the cams indicate the angle of the switching point The other cams can be adjusted manually or with the enclosed hook-spanner or similar tool
Position indication	 Internally: Scale on the gear train side of the camshaft Externally: Scale in viewing window (refer to «Dimensions»)
Electrical connections	- Refer to «Technical data»
Gear train	- Maintenance-free
Drive shaft	 Made of black-finished steel. Ready fitted to the front of the gear train Different versions available

- Different versions available
- Mounting and fixing Front of the gear train is used as the mounting surface - Actuator is secured via through-holes

Special versions for fitting potentiometer

 Fitting a
 Certain types of actuators are supplied ready prepared for fitting a potentiometer.

 These actuators differ from the basic type only in that the housing is higher and that they are prepared for accommodating a potentiometer. Accessories are not required. The required type of potentiometer is to be ordered as a separate item (refer to «Ordering»). In that case, the third digit after the dot in the actuator's type reference will change from «1» to «2».

 Example:
 SQN31.111A2700 → basic type

 SQN31.1112A2700 → version for fitting a potentiometer

Conversion by the user

Users have the choice of converting a basic type of actuator to a version for fitting a potentiometer. For that, a conversion kit type **AGA32** is available (refer to «Ordering»).



Attention!

Conversion of the basic type reference must be noted by the user on the actuator's type field using a permanent felt-tip pen.

Diagram	Drive	Running	Operating	Holding	HS	Relay	Housing	Types for mains voltage	ge / mains frequency
	shaft 1)	time	torque	torque	7)		length 1)	AC 220 V -15 %	AC 100 V -15 %
		at 50 Hz ²)	(max.)					AC 240 V +10 %	AC 110 V +10 %
no.	no.	for 90°	Nm	Nm	pcs.	pcs.	mm	5060 Hz ⁴⁾	5060 Hz ³⁾
		S							
0	0	4.5	1	0.8	3		125	SQN30.102A2700 ⁵)	
1	0	4.5	1	0.8	2	1	110	SQN30.111A2700	SQN30.111A1700
1	0	4.5	1.5	0.8	2	1	110	SQN30.111A3500 ⁹)	
2	0	4.5	1	0.8	1	2	110	SQN30.121A2700	SQN30.121A1700
2	0	4.5	1.5	0.8	1	2	110	SQN30.121A3500 ⁹)	
3	0	4.5	1	0.8	1	2	110	SQN30.131A2700	SQN30.131A1700
5	0	4.5	1	0.8	1	2	110	SQN30.151A2700	SQN30.151A1700
5	0	12	1.8	1.8	1	2	110	SQN30.251A2700	SQN30.251A1700
0	0	30	3	3	3		110	SQN30.401A2700	
0	3	30	3	3	3		110	SQN30.401A2730	
0	0	30	3	3	3		125	SQN30.402A2700 ⁵)	SQN30.402A1700 ⁵)
0	3	30	3	3	3		125	SQN30.402A2730 ⁵)	
1	0	30	3	3	2	1	110	SQN30.411A2700	
3	0	30	3	3	1	2	110	SQN30.431A2700	
5	0	30	3	3	1	2	110	SQN30.451A2700	

Actuators SQN30... / counterclockwise rotation 8)

Actuators SQN31... / clockwise rotation ⁸)

Diagram	Drive	Running	Operating	Holding	HS	Relay	Housing	Types for mains voltage	ge / mains frequency
-	shaft 1)	time	torque	torque	7)		length 1)	AC 220 V -15 %	AC 100 V -15 %
		at 50 Hz 2)	(max.)					AC 240 V +10 %	AC 110 V +10 %
no.	no.	for 90°	Nm	Nm	pcs.	pcs.	mm	5060 Hz ⁴⁾	5060 Hz ³⁾
0	0	4.5	1	0.8	3		110	SQN31.101A2700	SQN31.101A1700
0	0	4.5	1	0.8	3		125	SQN31.102A2700 ⁵)	SQN31.102A1700 ⁵)
1	0	4.5	1	0.8	2	1	110	SQN31.111A2700	
1	6	4.5	1	0.8	2	1	110	SQN31.111A2760	
2	0	4.5	1	0.8	1	2	110	SQN31.121A2700	
2	3	4.5	1	0.8	1	2	110	SQN31.121A2730	
2	6	4.5	1	0.8	1	2	110	SQN31.121A2760	
5	0	4.5	1	0.8	1	2	110	SQN31.151A2700	SQN31.151A1700
5	3	4.5	1	0.8	1	2	110	SQN31.151A2730	
2	0	12	1.8	1.8	1	2	110	SQN31.221A2700	
2	3	12	1.8	1.8	1	2	110	SQN31.221A2730	
5	0	12	1.8	1.8	1	2	110	SQN31.251A2700	SQN31.251A1700
5	3	12	1.8	1.8	1	2	110	SQN31.251A2730	
0	0	12	1,8	1,8	3		125	SQN31.202A2700 ⁵)	
5	0	12	1.8	1.8	1	2	125	SQN31.252A2700 ⁵)	SQN31.252A1700 ⁵)
5	0	15	2	1.8	1	2	110	SQN31.351A2700	
0	0	30	3	3	3		110	SQN31.401A2700	SQN31.401A1700
0	3	30	3	3	3		110	SQN31.401A2730	
0	6	30	3	3	3		110	SQN31.401A2760	
0	0	30	3	3	3		125	SQN31.402A2700 ⁵)	SQN31.402A1700 ⁵)
1	0	30	3	3	2	1	110	SQN31.411A2700	
1	3	30	3	3	2	1	110	SQN31.411A2730	
6	0	23	2.5	2.5		2	125	SQN31.762A2700 ⁵)	
4	0	120	6	6	2	1	110	SQN31.941A2700	

Autual	Actuators being recommiss rotation j								
Diagram	Drive	Running	Operating	Holding	HS	Relay	Housing	Types for mains voltage / mains frequency	
	shaft 1)	time	torque	torque	7)		length 1)	AC 220 V -15 %	AC 100 V -15 %
		at 50 Hz 2)	(max.)					AC 240 V +10 %	AC 110 V +10 %
no.	no.	for 90°	Nm	Nm	pcs.	pcs.	mm	5060 Hz ⁴⁾	5060 Hz ³⁾
4	0	120	6	6	2	1	110	SQN41.941A2700	

Actuators SQN41... / clockwise rotation 8)

Legend

1) Refer to «Dimensions»

²) At 60 Hz, running times are about 20 % shorter

³) AC 100...110 V +10 % / -15 % possible, but in case of undervoltage torque is reduced by about 20 %

4) AC 220...240 V +10 % / -15 % possible, but in case of undervoltage torque is reduced by about 20 %

⁵) Suited for fitting a potentiometer (refer to «Fitting a potentiometer»)

 $^{6})$ Under nominal conditions; under extreme conditions (e.g. +60 °C, AC 230 V –15 %) about –25 %

- ⁷) Optional auxiliary switches (in addition to the 2 end switches)
- ⁸) When facing the drive shaft and when control voltage is fed to end switch I
- $^{9})~$ On time at: ~ AC 220 V -15 % / +10 % and 50 Hz max. 50 %
 - AC 240 V -15 % / +10 % and 50 Hz max. 35 %

Ordering

Actuator

Potentiometer ASZ....

refer to «Type summary»

refer to Data Sheet N7921



Conversion kit AGA32	refer to Data Sheet N7921
- For converting a basic type of actuator to a version for fitt	ing a potentiometer
Example of conversion by the user:	

SQN30.401A2730 - Actuator (refer to «Type summary»)

AGA32 - Conversion kit

ASZ8.703 - Coiled potentiometer 220 Ω / 90°, 3-pole



Service kit AGA33 refer to Data Sheet N7921 - For replacing old potentiometers type ASZ...5... / ASZ...6... by new potentiometers type ASZ...7... and ASZ...8...

Technical data

General actuator data Actuator

End and auxiliary

Environmental conditions

switches

Mains voltage	AC 220240 V -15 % +10 %
	AC 100110 V -15 % +10 %
Mains frequency Primary fuse (external)	5060 Hz ±6 % 6.3 AT (customer responsible for
Filinary luse (external)	installation)
Type of motor	synchronous motor
Power consumption	6.5 VA
Angular position	max. 160°
Mounting position	optional
Degree of protection	IP 40 to DIN 40050, provided adequate
	cable entries and fixing screws are used
Safety class	I to VDE 0631
Cable entry	threaded cable gland holder for
	1 x Pg9 and 1 x Pg11, no locknut required
	cable strain relief to be provided by the us
	(also refer to «Degree of protection»),
	Pg glands for all types are included in the
	delivery
Cable connections	screw terminals for wires having a cross-
	sectional area of 0.5 to 2.5 mm ²
Ferrules	matching the dia. of the stranded wire
Direction of rotation	refer to «Type summary»
Torques and holding torques	refer to «Type summary»
Running times	refer to «Type summary»
Life cycle	Cycles (CLOSED ⇔ OPEN ⇔ CLOSED) at specified torque: typical 250,000
Weight (on average)	approx. 800 g
Number of end switches	2
Number of auxiliary switches	refer to «Type summary»
Actuation	via camshaft, color-coded cams (refer to
Actuation	«Connection diagrams»
Switching voltage	AC 24250 V
Adjustment of cams in increments of	1°
Perm. terminal rating at $\cos\varphi = 0.9$:	Peak current Operating current
Electronic circuit	
- under load ON, not under load OFF	Max. 14 A 2 A
- under load ON, under load OFF	Max. 7 A 1 A
Storage	DIN EN 60 721-3-1
Climatic conditions	class 1K2
Mechanical conditions	class 1M2
Temperature range	-20+60 °C
Humidity	< 95 % r.h.
Transport	DIN EN 60 721-3-2
Climatic conditions	class 2K2
Mechanical conditions	class 2M2
Temperature range	-20+60 °C
Humidity	< 95 % r.h.
Operation	DIN EN 60 721-3-3
Climatic conditions	class 3K3
Mechanical conditions	class 3M3
Temperature range	-20+60 °C
Humidity	< 95 % r.h.



Attention! Condensation, formation of ice and ingress of water are not permitted! A synchronous motor drives the drive shaft and the camshaft via a gear train. The attached camshaft actuates the end and auxiliary switches. The switching position of each end and auxiliary switch can be adjusted within its working range via the associated cam. Some of the actuator versions are equipped with electronic modules for auxiliary functions in connection with the end and auxiliary switches or with external devices, such as controllers (refer to «Connection diagrams»). The functions and technical data of both lines of actuators SQN3... and SQN4... are nearly identical.

Connection diagrams

Note!

- The following connection diagrams show the actuator's start position as supplied:
- End switch position II (CLOSED)

- Dead

No. $\bigcirc \rightarrow$ LFL... / LGK16... / LAL... and LOK16...



2-stage or modulating operation → Prepurging at nominal load position «NL»

- 1) Diagram shows arrangement for modulating operation
- *) Thermostat or similar with changeover contact (2-wire control) or 3-position controller for «on / off» positioning pulses and neutral position
- **) In case of modulating operation, fuel valve «BV2» is replaced by a gas control valve «RV»



Program sequence diagram shows modulating operation

No. $\bigcirc \rightarrow$ LFL... / LGK16... / LAL... / LOK16...

2-stage operation \rightarrow Prepurging at nominal load position «NL»



) Thermostat or similar with NO contact (1-wire control)

No. $\bigcirc \rightarrow LOA24... / LOA25... / LOA28... / LMO24... / LMO44...$

2-stage operation \rightarrow Prepurging at low-fire position «KL»



- 1) With oil preheater
- 2) Without oil preheater
- *) Thermostat or similar with NO contact (1-wire control)

3) Cams III and IV are rigidly connected



No. $\bigcirc \rightarrow LMG21... / LMG25... / LGB21...$

2-stage operation \rightarrow Prepurging at low-fire position «KL»



No. $\bigcirc \rightarrow LMG22... / LGB22... / LGB32...$



2-stage or modulating operation \rightarrow Prepurging at nominal load position «NL»

- Diagram shows arrangement for modulating operation
- Thermostat or similar with changeover contact (2-wire control) or 3-position controller for «on / off» positioning pulses and neutral position
- **) In case of 2-stage modulating burners (with gas damper «RV»), «BV2» and the connection between the terminals (shown as a broken line) will not be needed

Program sequence diagram shows modulating operation

7808d14/1204



No. $\textcircled{6} \rightarrow \mathsf{LMG22...}$ / LGB22... / LGB32...

Modulating operation \rightarrow Prepurging at nominal load position «NL»



Diagram shows arrangement for modulating operation

The cams of switches III and V are rigidly connected. This ensures that ignition takes place at the low-fire position «KL»

Thermostat or similar with changeover contact (2-wire control) or 3-position controller for «on / off» positioning pulses and neutral position

Program sequence diagram shows modulating operation

Attention!

If the contacts of switch V welded in position $4 \rightarrow 9$, supervision of the ignition load position would be negated and not be detected in operation. This means that the circuit is not safety-related but only used for supervision purposes. The user must ensure that in the event of failure (should the burner ignite at nominal load «NL»), no damage will occur.

No. $\textcircled{4} \rightarrow$ Special application



No. $\bigcirc \rightarrow$ TMG740 / TMO720 (burner control of other manufacture)



2-stage operation \rightarrow Prepurging at nominal load position «NL»

SQN3x.x3xAxxxx



- 1) Cams of switches III and IV are rigidly connected
- 2) TMO720 terminal no. 6 TMG740 terminal no. 21

 TMG... and TMO... are devices of other manufacture, neither made nor supplied by Siemens. Combination with the type of Siemens actuator proposed here must be checked with the supplier of the TMG... or TMO... while taking into consideration safety aspects and the current burner control version.

The user assumes full responsibility for this application.

Legend	No. 🖉	Number of internal diagram
		(second position after the dot in the actuator's type reference)
	1711	End switch
	III / IV / V	Auxiliary switch
	AL	Remote indication of fault (alarm)
	BV1	Fuel valve stage 1
	BV2	Fuel valve stage 2
	EK2	External remote reset button
	ION	Ionization probe
	FS	Flame signal amplifier
	GL	Gas / air ratio controller
	GP	Gas pressure switch
	HS	Main switch
	KL	Low-fire
	L	Live conductor
	LK	Air damper
	LKP	Air damper position
	LP	Air pressure switch
	LR	Load controller
	Μ	Burner or fan motor
	M	Actuator's synchronous motor
	M1	Without postpurging
	M2	With postpurging
	Ν	Neutral conductor
	NL	Nominal load
	ОН	Oil preheater
	OW	Oil preheater's readiness contact
	QRB	Photoresistive flame detector
	R	Temperature or pressure controller
	¢	Relay
	RV	Gas damper
	SA	Actuator
	Si	External primary fuse (as specified in the Data Sheet of the relevant burner control)
	SB	Safety limiter
	ST	Stage
	t / T	Program times (refer to the Data Sheet of the relevant burner control)
	TSA	Safety time
	R	Resistance
	Z	Ignition transformer
	ZU	Damper fully closed
		Direction of rotation OPEN
	▼	Direction of rotation CLOSE

Program sequence diagrams

- A Burner ON
- A B Startup of burner
- B C Burner operation / load control operation (modulating or 2-stage)
- C Burner OFF
- C D Overrun time
- D End of program sequence, burner control ready for a new start



All drive shafts are shown in end switch position II (CLOSED, as supplied).

- 1) Housing length depending on type of actuator (refer to «Type summary»)
- Center slot: 6.3 mm deep Hole dia. 5.1 mm: 16.5 mm deep (incl. center slot depth)
- 3) Not included in delivery

- R Fixing positions
- M Through-hole 5.3 mm dia.